

September 15, 2005

Camozzi Bros.  
c/o Century 21 Bundesen Realty  
616 Petaluma Blvd. So.  
Petaluma, CA 94952

Re: Report of Well Test

Dear Camozzi Bros.:

Enclosed please find the well test recently completed at **6188 Bodega Ave. in Petaluma, upper well and lower well**. The water sample results should be available shortly and will be sent immediately upon our receipt.

Sincerely,

Jim Mickelson  
Jerry & Dons Yager Pump & Well

JM/st

Encl.



**DRAFT**

**Jerry & Don's Yager Pump and Well  
1290 Bodega Ave - Petaluma, CA  
REPORT OF WELL TEST**

Date **09/15/05**

Owners Name	<b>Camozzi Bros.</b>
c/o	<b>Century 21 Bundesen Realty</b>
Mailing Address	<b>616 Petaluma Blvd. So. – Petaluma, CA 94952</b>
Job Address	
Location of Well	<b>6188 Bodega Ave. – Petaluma – Lower Well</b>

**WELL INFORMATION**

Drilled Well	<input checked="" type="checkbox"/>	Hand Dug	<input type="checkbox"/>	Spring	<input type="checkbox"/>
Well Depth	<b>100'</b>	Casing Size & Type	<b>8" Steel</b>		
Static Water Level	<b>3'</b>	Pumping Water Level	<b>87'</b>	after <b>1.5</b> hours pumping	
Yield of Water Source	<b>2.1 gpm</b>				
Water Samples Taken:	<input checked="" type="checkbox"/> Bacteria	<input checked="" type="checkbox"/> Nitrate	<input checked="" type="checkbox"/> Other	<b>Basic Mineral</b>	

**PUMP INFORMATION**

Method of Test	Jet	Submersible	<input checked="" type="checkbox"/>	Pump Model	<b>Goulds 10LS07412</b>
Pump Setting	<b>90'</b>	Pump Production	<b>20.6 GPM</b>	Open Discharge at	
Pump Static Pressure	<b>145 PSI</b>	Pressure Tank Type & Size	<b>Goulds V – 200</b>		
Storage Tank Type/Size		Booster Pump Type & Size			
Booster Pump Capacity		Operating Pressure Setting	<b>30 – 50</b>		
Water Treatment Equipment (Filter, UV Light, Chlorinator, Etc)					

**COMMENTS**

**Water is clear and very little sediment. No recommendations.**

By:

This report is for informational use only. It is in lieu of, and supersedes any other representation or statements of the agents or employees of the company, and all other such representations or statements shall be relied upon at the Customer's own risk.

The data and conclusions provided herein are based upon the best information available to the company using standard and accepted practices of the water well drilling industry. However, conditions in water well are subject to dramatic changes even in short periods of time. Therefore, the data and conclusions are valid only as of the date of the test or installation indicated, and should not be relied upon to predict either the future quality or quantity of water that the well will produce.

The company makes no warranties, either express or implied, as to such future water production, and expressly disclaims and excludes any liability for consequential or incidental damages arising out of the breach of any express or implied warranty of future water production, or out of any further use of this report by the customer.

California State License: **C-57 C-36 761309**  
Phone (707) 762-1473 Fax (707) 769-9102

09/15/05

# Jerry & Don's Yager Pump and Well

## 1290 Bodega Ave - Petaluma, CA

Phone (707) 762-1473 Fax (707) 769-9102  
C57 - 761309

### WATER ANALYSIS REPORT

**Date:** 09/15/05

**Customer:** Camozzi Bros. c/o Century 21 Bundesen Realty

**Address:** 616 Petaluma Blvd. So.

**City & State:** Petaluma, CA 94952

**Location of Sample:** 6188 Bodega Ave. - Petaluma - Lower Well

**Sample Taken By:** Jason Wright

#### Recommended Levels

Bacteria ( Coliform )                      47.8 Less than 1 M.P.N  
Bacteria ( E. Coli )                         ABSENT Less than 1 M.P.N

#### Physical Appearance of Sample

**Clear:** \_\_\_\_\_ **Excessive Solids:** \_\_\_\_\_

**Slight Turbidity:** \_\_\_\_\_ **Cloudy:** \_\_\_\_\_

#### Comments

**Bacteriological Interpretation - Contaminated**

**Jerry & Don's Yager Pump and Well  
1290 Bodega Ave - Petaluma, CA  
REPORT OF WELL TEST**

Date **09/15/05**

Owners Name	<b>Camozzi Bros.</b>
c/o	<b>Century 21 Bundesen Realty</b>
Mailing Address	<b>616 Petaluma Blvd. So. – Petaluma, CA 94952</b>
Job Address	
Location of Well	<b>6188 Bodega Ave. – Petaluma – Upper Well</b>

**WELL INFORMATION**

Drilled Well	<input checked="" type="checkbox"/>	Hand Dug	<input type="checkbox"/>	Spring	<input type="checkbox"/>
Well Depth	<b>200'</b>	Casing Size & Type	<b>6" Steel</b>		
Static Water Level	<b>100'</b>	Pumping Water Level	<b>180'</b>	after 1.5 hours pumping	
Yield of Water Source	<b>3 gpm at 180'</b>				
Water Samples Taken:	<input checked="" type="checkbox"/> Bacteria	<input checked="" type="checkbox"/> Nitrate	<input checked="" type="checkbox"/> Other	<b>Basic Mineral</b>	


**PUMP INFORMATION**

Method of Test	<input type="checkbox"/> Jet	<input checked="" type="checkbox"/> Submersible	<b>5 GPM ½ HP Sub</b>
Pump Setting	<b>180'</b>	Pump Production	<b>8.3 GPM</b>
Pump Static Pressure	<b>130'</b>	Pressure Tank Type & Size	<b>WX – 250</b>
Storage Tank Type/Size		Booster Pump Type & Size	
Booster Pump Capacity		Operating Pressure Setting	<b>20 – 40</b>
Water Treatment Equipment (Filter, UV Light, Chlorinator, Etc)			

**COMMENTS**

**Water is a little rusty. Recommend replacing disconnect to be able to run well and place all wires in conduit. Also need to install sanitary well seal and pressure relief valve. Pump is bleeding back also.**

By: \_\_\_\_\_



This report is for informational use only. It is in lieu of, and supersedes any other representation or statements of the agents or employees of the company, and all other such representations or statements shall be relied upon at the Customer's own risk.

The data and conclusions provided herein are based upon the best information available to the company using standard and accepted practices of the water well drilling industry. However, conditions in water well are subject to dramatic changes even in short periods of time. Therefore, the data and conclusions are valid only as of the date of the test or installation indicated, and should not be relied upon to predict either the future quality or quantity of water that the well will produce.

The company makes no warranties, either express or implied, as to such future water production, and expressly disclaims and excludes any liability for consequential or incidental damages arising out of the breach of any express or implied warranty of future water production, or out of any further use of this report by the customer.

**California State License: C-57 C-36 761309  
Phone (707) 762-1473 Fax (707) 769-9102**

spoke to Karl @

2:20 9/19 - He said

no treatment @

this time (D)

**Jerry & Don's Yager Pump and Well**  
**1290 Bodega Ave - Petaluma, CA**  
 Phone (707) 762-1473 Fax (707) 769-9102  
 C57 - 761309

**WATER ANALYSIS REPORT**

**Date:** 09/15/05

**Customer:** Camozzi Bros. c/o Century 21 Bundesen Realty

**Address:** 616 Petaluma Blvd. So.

**City & State:** Petaluma, CA 94952

**Location of Sample:** 6188 Bodega Ave. - Petaluma - Upper Well

**Sample Taken By:** Jason Wright

**Recommended Levels**

<b>Bacteria ( Coliform )</b>	<u>&gt;200.5</u> Less than 1 M.P.N
<b>Bacteria ( E. Coli )</b>	<u>ABSENT</u> Less than 1 M.P.N

**Physical Appearance of Sample**

**Clear:** Excessive Solids:

**Slight Turbidity:** Cloudy:

**Comments**

**Bacteriological Interpretation - Contaminated**